



Keymark Certificate



078/000413

AENOR certifies that the organization

BDR THERMEA GROUP B.V.

registered office MARCHANTSTRAAT, 55 7300 AA APELDOORN (Holanda - Países Bajos)

supplies **Solar collectors**

in compliance with UNE-EN 12975-1:2006+A1:2011 (EN 12975-1:2006+A1:2010)

Trade Mark REMEHA C200 V
Technical information Specified in Annexes to the Certificate

Production site CL MANGANÈS, 2 08755 CASTELLBISBAL (Barcelona - España)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 078.01.

First issued on 2023-06-14
Validity 2028-06-14

Rafael GARCÍA MEIRO
CEO





Annex to Solar Keymark Certificate Supplementary Information	Licence Number	078/000413
	Issued	2023-06-14

Gross Thermal Yield in kWh/collector at mean fluid temperature ϑ_m													
Collector name	Standard Locations	Athens			Davos			Stockholm			Würzburg		
	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
REMEHA C200 V		2.440	1.722	1.109	1.837	1.250	769	1.356	874	518	1.484	950	554
Gross Thermal Yield per m ² gross area		1.214	857	552	914	622	383	675	435	258	738	472	275
Annual efficiency, η_a		69%	49%	31%	56%	38%	23%	58%	37%	22%	59%	38%	22%
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m ²			1630 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²		
Mean annual ambient air temperature		18,5°C			3,2°C			7,5°C			9,0°C		
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.2 (13.01.2022). A detailed description of the calculations is available at <http://www.estif.org/solarkeymarknew/>

Additional Information					
Collector heat transfer medium	Water-Glycole				
The collector is deemed to be suitable for roof integration	No				
The collector was tested successfully under the following conditions:					
Climate class (A+, A, B or C)	A		--		
G (W/m ²) >	1000	ϑ_a (°C) >	20	H_x (MJ/m ²) >	600
Maximum tested positive load	3500		Pa		
Maximum tested negative load	2400		Pa		
Hail resistance using ice balls (diameter)	35		mm		

Additional collector attribute(s)			
Using external power source(s) for normal operation	No	Active or passive measure(s) for self-protection	No
Co-generating thermal and electrical power	No	Façade collector(s)	Yes

Energy Labelling Information		Additional Informative Technical Data	
	Reference Area, A_{sol} (m ²)	Hydraulic Designation Code	Aperture Area, A_a (m ²)
REMEHA C200 V	2,01	1-H-1234S-A:7.2,16085-C:16.6,1100	1,89

Data required for CDR (EU) No 811/2013 - Reference Area		Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}	
Collector efficiency (η_{col})	58%	Zero-loss efficiency (η_0)	0,75
Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.		First-order coefficient (a_1)	3,72
		Second-order coefficient (a_2)	0,012
		Incidence angle modifier IAM (50°)	0,93
		Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.	